

Hoshiarpur.

Phone/FAX No.01882-240484 email:-eewss.div1hoshiarpurb@yahoo.com

To

The Principal,
Sukh Sagar International Public School,
Village Saidowal, Tehsil Dasuya,
Distt. Hoshiarpur.


No. 3377 date :- 30/5/23

Sub :- **Issue of a health and sanitary certificate for the session 2023-24.**

Ref. T.O letter No.492 dt.29.05.23 and your application No.SSIPS/2023-24/Misc/07 dt. 26.05.2023

It is pertaining to the subject cited above that the building of **Sukh Sagar International Public School, Village Saidowal, Tehsil Dasuya, Distt. Hoshiarpur** has been inspected by this office and the health & sanitation condition is found quite satisfactory for the **year 2023-24.**


The authority has provided potable water for drinking.


Executive Engineer,
W/S & Sanitation Divn. No.1,
Hoshiarpur.

Endst. No. dt.

A copy of the above is forwarded to **Sub Divisional Engineer, W/S & Sanitation Sub Division Dasuya** w.r.t. their letter No.492 dated 29.05.2023 for information.

Verified


Principal
For Sukh Sagar International Sen. Sec.
Public School, (A.I. No. 1630489)
Saidowal (Dasuya) Distt. Hoshiarpur

-sdr
Executive Engineer,
W/S & Sanitation Divn. No.1,
Hoshiarpur.

Roinder Teer
Chairperson / Secretary
For Sukh Sagar International Sen. Sec.
Public School, (A.I. No. 1630489)
Saidowal (Dasuya) Distt. Hoshiarpur

REGIONAL WATER TESTING LAB, HOSHIARPUR

Government III, Jalandhar Road, Hoshiarpur
rwtlhsp@gmail.com



TEST REPORT

Name & Address of Customer:
Sukh Sagar International Public School
Vill. Soidowal, P.O. Saldarpur, Teh. Dasuya, Distt.
Hoshiarpur

Customer Reference No.: No: 551P/2023-2024/MISC/C5 Dated: 26/05/2023
Sample Submitted by: Arjinder Singh
Date of Sample Receipt: 26/05/2023
Analysis Starting Date: 26/05/2023
Analysis completion Date: 27/05/2023

Discipline: Chemical Testing

ULR No: TCS77923000000483F

Test Report No.: RWTLHSP/2324/00172

Registration no.: RWTLHSP/REG2324/00232

Collection Point: Treatment Plant
(RO/CWPP/ARP/HH Purifier)

Schema/Source: Not Mentioned (Not Mentioned)

Village: SAIDOWAL

Block: Dasuya

Latitude: Not Mentioned

Group: Water

Sample Type: Water

Date of Issue: 29/05/2023

Condition of Sample: Unsealed

Quantity/Type of Bottle: 1000 ml / Amber Coloured Sample Bottle - 500 ml

Location/Depth: Vill. Soidowal, P.O. Saldarpur, Teh. Dasuya, Distt. Hoshiarpur / NH

Habitation: SAIDOWAL

District: Hoshiarpur

Longitude: Not Mentioned

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference / Action
			Acceptable Limit	Permissible Limit		
1	Colour	1	5	15	CU	IS 3025 (Part 4-2011) Visual Comparison Method
2	Odour	Agreeable	Agreeable	Agreeable		IS 3025 (Part 5-2011) (Second Revision)
3	Taste	Agreeable	Agreeable	Agreeable		IS 3025 (Part 8-1984) (RA 2017)
4	TDS	153.0	500	2000	mg/l	IS 3025 (Part 16-1984) Gravimetric Method
5	Turbidity	BDL	1	5	NTU	IS 3025 (Part 10-1984) Nephelometric Method
6	Alkalinity	133.12	200	600	mg/l	IS 3025 (Part 23-1986) Indicator Method
7	Hardness	112.52	200	600	mg/l	IS 3025 (Part 21-2013) EDTA Method
8	Calcium	26.43	75	200	mg/l	IS 3025 (Part 40-1991) EDTA Titrimetric Method
9	Magnesium	11.31	30	100	mg/l	APHA (23rd Ed 2017) Method: 3500-Mg-2 G By Calculation Method
10	Chloride	16.22	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition:

- The results apply to the sample as received only.
- The sample will be destroyed after retention time unless otherwise specified specially.
- This report is not to be reproduced, wholly or in part and can't be used as evidence in court of law.
- Abbrevial or used: TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below Detectable Limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable, NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND = Not Detected.
- * Value not available or test not performed for this parameter.
- Temperature condition limit: 25-30°C and Humidity condition limit: 50-70%.

Verified

Principal
For Sukh Sagar International Sen. Sec.
Public School, (All. No. 1630489)
Saidowal (Dasuya) Distt. Hoshiarpur

Mr. Jivesh Kumar
Quality Manager
Authorized Signatory
For Regional Water Testing Lab, Hoshiarpur

Rajinder To

Chairperson / Secretary
For Sukh Sagar International Sen. Sec.
Public School, (All. No. 1630489)
Saidowal (Dasuya) Distt. Hoshiarpur

End of the Test Report

REGIONAL WATER TESTING LAB, HOSHIARPUR

Government ITI, Jalandhar Road, Hoshiarpur
rwtlhsp@gmail.com

TEST REPORT


Name & Address of Customer :- Sukh Sagar International Public School Vill. Saidowal, P.O. Safdarpur, Teh. Dasuya, Distt. Hoshiarpur	Customer Reference No. No : SSIP/2023-2024/MISC/06 Dated : 26/05/2023	Sample Submitted by : Arjinder Singh Date of Sample Receipt : 26/05/2023 Analysis Starting Date : 26/05/2023 Analysis completion Date : 27/05/2023
---	---	---

Discipline : Bacteriological Testing	Group : Water	
ULR No. :	Sample Type :	Water
Test Report No. : RWTLHSP/2324/00172	Date of Issue :	29/05/2023
Registration no. : RWTLHSP/REG2324/00232	Condition of Sample :	Unsealed
Collection Point : Treatment Plant (RO/CWPP/ARP/HH Purifier)	Quantity/Type of Bottle :	1000 ml / Amber Coloured Sample Bottle - 500 ml
Scheme/Source : Not Mentioned(Not Mentioned)	Location/Depth :	Vill. Saidowal, P.O. Safdarpur, Teh. Dasuya, Distt. Hoshiarpur / NA
Village : SAIDOWAL	Habitation :	SAIDOWAL
Block : Dasuya	District :	Hoshiarpur
Latitude : Not Mentioned	Longitude :	Not Mentioned

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method
			Acceptable Limit	Permissible Limit		
1	Bacteriological Contamination	Absent				IS 10500

This Report is issued under the following terms & Condition:

- The results apply to the sample as received only.
- The sample will be destroyed after retention time unless otherwise specified specially.
- This report is not to be reproduced wholly or in part and can't be used as evidence in court of law.
- Abbreviations used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS Indian Standard, NT = Not Tested, NA = Not Applicable, NTU = Nephelometric Turbidity Unit, BA = Bacteria, ND = Not Detected).
- * Value not available or test not performed for this parameter.
- Temperature condition limit: 25±5°C and Humidity condition limit: 50 ± 20%


Mr. Jivesh Kumar
 Quality Manager
 Authorized Signatory
 For, Regional Water Testing Lab, Hoshiarpur

End of the Test Report